

LESSONS LEARNED FROM LOSSES

MAY 2019 – MOLD PREVENTION



NO MOLD



7th Annual Mold/Environmental Management Seminar – 7/17/19

- Summer and it's hot and humid conditions are coming.
- Control the moisture to prevent the mold. Mold needs moisture.
- Building temperatures should be maintained between 68F and 79F with humidity levels under 60%.
- Please check the exterior of your buildings frequently for loose building materials that could allow water to enter.
- Check the foundation for cracks and make sure they are sealed properly.
- Insulate areas where condensation forms such as pipes and ductwork.
- Ensure all HVAC systems are maintained as per manufacturer recommendations.
- Areas where building maintenance activities that use water are taking place, such as mopping, carpet cleaning or floor stripping, should be well ventilated.